

FS-209E 标准的空气中悬浮粒子洁净度等级

NO.	等级名称		等 级 限 值									
			0.1		0.2		0.3		0.5		5	
	容积单位		容积单位		容积单位		容积单位		容积单位			
	国际单位	英制单位	m ³	ft ³	m ³	ft ³	m ³	ft ³	m ³	ft ³	m ³	ft ³
1	M1		350	9.91	75.7	2.14	30.9	0.875	10	0.283	—	—
2	M1.5	1	1240	35	265	7.5	106	3	35.3	1	—	—
3	M2		3500	99.1	757	21.4	309	8.75	100	2.83	—	—
4	M2.5	10	12400	350	2650	75	1060	30	353	10	—	—
5	M3		35000	991	7570	214	3090	87.5	1000	28.3	—	—
6	M3.5	100	—	—	26500	750	10600	300	3530	100	—	—
7	M4		—	—	75700	2140	30900	875	10000	283	—	—
8	M4.5	1000	—	—	—	—	—	—	35300	1000	247	7
9	M5		—	—	—	—	—	—	100000	2830	618	17.5
10	M5.5	10000	—	—	—	—	—	—	353000	10000	2470	70
11	M6		—	—	—	—	—	—	1000000	28300	6180	175
12	M6.5	100000	—	—	—	—	—	—	3530000	100000	24700	700
13	M7		—	—	—	—	—	—	10000000	283000	61800	1750

备注:本次工程验收参考洁净度等级标准NO.8.